



CITY OF OSHKOSH FIRE DEPARTMENT FOOD VENDOR REQUIREMENTS

ALL REQUIREMENTS ARE PER THE 2009 INTERNATIONAL FIRE CODE

ALL Tents Must:

- 1) Be certified FLAME RESISTANT.
- 2) Have a “NO SMOKING” sign posted.
- 3) Be placed 20 FEET from another tent, structure, vehicle, or cooking area.

NO EATING IS ALLOWED IN ANY TENT IN WHICH COOKING TAKES PLACE UNLESS PREVIOUSLY APPROVED BY THE FIRE DEPARTMENT.

Fire Extinguisher(s) Required:

- 1) A minimum of one 2.5 # dry chemical (2A) ABC fire extinguisher is required.
- 2) If more than 1 pint of cooking oil/grease is used, one type ‘K’ fire extinguisher is required.

Allowable Distances of Other Cooking Areas From Any Structures (Including Tents):

- 1) Charcoal cooking – 20 FEET.
- 2) LP gas (NOT cooking with oil/grease)
 - LESS THAN OR EQUAL TO 500 GALLON container of LP—10 FEET
 - GREATER THAN 500 GALLON container of LP—25 FEET
- 3) LP or electric (cooking with oil/grease) – 20 FEET.
- 4) Electric cooking (NOT cooking with oil/grease) – 10 FEET.

ALL VIOLATIONS MUST BE CORRECTED IMMEDIATELY

PLEASE NOTE:

This is not a complete listing of the fire regulations, only an example of commonly violated regulations. The Fire Chief may modify the above regulations. The fire Chief has the ultimate authority of regulations by Local & State Law.

**Mike Augsburger, Battalion Chief
Fire Prevention Bureau, City of Oshkosh Fire Department
(920) 236-5241**